

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 14	Township number T 18 S R 36 E W	Range number
2. Distance and direction from nearest town or city: 2 1/2 W, 1/2 N of			3. Owner of well: M. O. Nuss			
Street address of well location if in city: Marienthal, Kansas			R.R. or street: City, state, zip code: Great Bend, KS 67530			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 24 in. Completion date _____ Well depth 127 ft. 8/8/77	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	8	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 17.5 lbs./ft. Dia. 12 in. to 127 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 134		
Gyp		8	17	10. Screen: Manufacturer's name _____ Free Flow Type Prime Steel Dia. 12 in. Slot gauze .179 Length 20 ft. Set between 107 ft. and 127 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 5/8-1/4		
Sd cemented		17	21	11. Static water level: 5-16-77 mo./day/yr. 82 ft. below land surface Date 5-16-77		
Sand		21	29	12. Pumping level below land surfaces: 109 ft. after 8 hrs. pumping 300 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 300 g.p.m.		
Sd cemented		29	33	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Gyp rock		33	51	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Sd cemented		51	63	15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Fine sd clay stks		63	99	16. Nearest source of possible contamination: Feed ft. 1600 Direction SW Type Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sand medium		99	102	17. Pump: _____ Not installed Manufacturer's name Goulds Model number JH66LL34 HP 10 Volts 460 Length of drop pipe 125 ft. capacity 300 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
Sand cemented		102	121	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address Scott City, KS 67871 Authorized representative [Signature] Date 8-24-77		
Fine sd clay stks		121	123			
Clay yellow		123	130			
Shale		130				
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 18
 R 36
 S 14
 Sec 14
 NE 1/4
 SE 1/4
 NW 1/4
 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWG-5