


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Wichita	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 17	Township number T 18 S R 37 E/W	Range number
② Distance and direction from nearest town or city: Street address of well location if in city:		3. Owner of well: R.R. or street: City, state, zip code:			
4 1/2 N 1/2 E of Lakin, Ks. Lakin		Delmer Mehl Box 166 Ellsworth Kansas 67439			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: 		6. Bore hole dia. 26 in. Completion date Well depth 210 ft. 7/23/76	
5. Type and color of material		From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
clay		0	20	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
gyp		20	60	9. Casing: Material steel Height Above or Below ### Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.86 lbs./ft. Dia 16 in. to 210 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219	
sandy clay		60	120	10. Screen: Manufacturer's name Lakewood Type Millslot Dia. 16 Slot ### 1/8x2" Length 80 Set between 130 ft. and 210 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 2x1/2	
med. sand, little clay 20		120	140	11. Static water level: <input type="checkbox"/> mo./day/yr. 150 ft. below land surface Date 6/2/76	
coarse sand & gravel (loose) 60		140	210	12. Pumping level below land surfaces: 197 ft. after 10 hrs. pumping 1100 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1100 g.p.m.	
shale at 198				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type NA Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Worthington Model number 38-121-90HP Volts <input type="checkbox"/> Length of drop pipe 190 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 2% grade to E		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply, Inc. 136A Business name License No. 402 Nth 1st St. Garden City, Ks. 67846 Address Signed B. D. Hubman Date 8-7- Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5