

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.


LEOTI NW

WATER WELL RECORD
KSA 82a-1201-1215

BDC

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Wichita	Township name Leoti	Fraction SW-SE$\frac{1}{4}$, NW$\frac{1}{4}$	Section number 18	Town number T 18 S	Range number R 37 W																														
Distance and direction from nearest town or city: 4 West, $\frac{1}{2}$ north of Leoti, Ks.				3 Owner of well: Jaeger Farms Address: Ray Jaeger Leoti, Ks.																																
Locate with "X" in section below: 				4 Well depth: 185 ft. Date of completion 3-16-75 Well diameter 26 in.																																
2 Type and color of material <table border="1"><thead><tr><th></th><th>From</th><th>To</th></tr></thead><tbody><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td></tr></tbody></table>					From	To																												5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
					From	To																														
6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well																																				
7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 186 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 36.87 lbs./ft. 1																																				
8 Screen: Manufacturer Johnson Division Type Galv. Dia. 16" Slot/gauze 20' Length 20' Set between 155 ft. and 175 ft. Perforations: 140-155, 175-185 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4" down																																				
9 Static water level: 138 ft. below land surface Date 2-18-75																																				
10 Pumping level below land surfaces: 160 ft. after 2 hrs. pumping 483 g.p.m. 167 ft. after 4 hrs. pumping 545 g.p.m. Estimated maximum yield 600 g.p.m.																																				
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date																																				
12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade																																				
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.																																				
14 Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																																				
15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																				
16 Remarks: elevation BROCK 185 3378 (TOPO) Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. Address Box 493 Garden City, Ks. Signed James Wilson Date 5-20-75 Authorized representative																																

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Richiat County Jaeger Farms February 18, 1975

SE $\frac{1}{4}$ SE $\frac{1}{4}$ N $\frac{1}{4}$ sec. 18 T. 18 R. 37 Static Water Level 138

Location: Halfway Between first test & Third Test.

Test # 5

0	3	Top Soil
3	19	Clay
19	27	GYP
27	30	Sand
30	35	Sandy GYP
35	50	GYP
50	55	Gray Clay
55	67	Red Sandy GYP
67	85	Fine Sand with Clay
85	91	Sand Medium with Clay
91	100	Sandy Clay
100	110	Fine Sand (Dirty)
110	121	Sandy Clay
121	125	Sand Dirty
125	133	Sand
133	135	Clay
135	145	Sand with Clay Streaks
145	150	Clean (Loose) Sand
150	155	Fine Sand
155	172	Coarse (Loose) Sand, a little Clay
172	181	Clear (Loose) Sand
181	190	4' Yellow, 5' Blue