


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 6620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Wichita	SE SW 1/4 SE 1/4 SE 1/4	4	T 18 S	R 38 E 1/4
2. Distance and direction from nearest town or city:	6W, 2N, 2W of Leoti, KS	3. Owner of well:	Frank Whitham Box Q Leoti, KS 67861		
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. 24 in. Completion date 2-13-75 Well depth 200 ft.	
			<p>7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug  <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry  <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock  <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material Steel Height: Above or below  Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in.  RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 217.5 lbs./ft.  Dia. 12 in. to 200 ft. depth Wall Thickness: inches or  Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 134</p> <p>10. Screen: Manufacturer's name Free Flow  Type Prime Steel Dia. 16 12 in.  Slot/gauze .179 Length 40 ft.  Set between 160 ft. and 200 ft.  ft. and <input type="checkbox"/> ft.  Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 3/4-1</p> <p>11. Static water level: mo./day/yr.  135 ft. below land surface Date 11-25-74</p> <p>12. Pumping level below land surfaces:  176 ft. after 4 hrs. pumping 950 g.p.m.  179 ft. after 4 hrs. pumping 1000 g.p.m.  Estimated maximum yield 1000 g.p.m.</p> <p>13. Water sample submitted: mo./day/yr.  Yes <input checked="" type="checkbox"/> No Date</p> <p>14. Well head completion:  Pitless adapter 12 Inches above grade</p> <p>15. Well grouted? <input checked="" type="checkbox"/>  With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete  Depth: From 0 ft. to 15 ft.</p> <p>16. Nearest source of possible contamination:  ft. 3960 Direction NW Type Septic  Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>17. Pump: Not installed  Manufacturer's name Simmons  Model number GE HP 75 Volts 110  Length of drop pipe 190 ft. capacity 1000 g.p.m.  Type:  <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine  <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating  <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p> <p>18. Elevation:  Topography:  <input type="checkbox"/> Hill  <input type="checkbox"/> Slope  <input checked="" type="checkbox"/> Upland  <input type="checkbox"/> Valley</p> <p>19. Remarks:  Sd coarse 179 195  Clay yellow 195 202  Shale 202 205</p> <p>20. Water well contractor's certification:  This well was drilled under my jurisdiction and this report  is true to the best of my knowledge and belief.  Weishaar Drilling 232  Business name Scott City, KS 67871  License No.  Address  Signed <i>John Weishaar</i> Date 7-19-76  Authorized representative</p>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5