


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 4	Township number T 18 S R 38	Range number E 10
2. Distance and direction from nearest town or city: 3N, 1/2E, 1/2S of Street address of well location if in city: Selkirk, KS			3. Owner of well: Frank Whitham R.R. or street: Box Q City, state, zip code: Leoti, KS 67861			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>2-10-75</u> Well depth <u>205</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	17	9. Casing: Material <u>Steel</u> Height: <u>10</u> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.62</u> lbs./ft. Dia. <u>16</u> in. to <u>205</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>205</u> ft. depth gage No. <u>188</u>		
Gyp		17	33	10. Screen: Manufacturer's name <u>Johnson</u> <u>Calv. & Prime</u> Type <u>Steel</u> Dia. <u>16</u> in. <u>100 & 125</u> Length <u>40</u> ft. Set between <u>165</u> ft. and <u>205</u> ft. ft. and <u>205</u> ft. Gravel pack? <u>yes</u> Size range of material <u>3/4-1/2</u>		
Rock H		33	36	11. Static water level: <u>132</u> ft. below land surface Date <u>11-12-74</u> mo./day/yr.		
Gyp		36	52	12. Pumping level below land surfaces: <u>162</u> ft. after <u>4</u> hrs. pumping <u>300</u> g.p.m. <u>190</u> ft. after <u>4</u> hrs. pumping <u>430</u> g.p.m. Estimated maximum yield <u>430</u> g.p.m.		
Clay		52	88	13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>11-12-74</u> mo./day/yr.		
Fine sd clay		88	97	14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter		
Clay		97	105	15. Well grouted? <u>Y</u> With: <u>Neat cement</u> <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>15</u> ft.		
Fine sd clay		105	112	16. Nearest source of possible contamination: ft. <u>2640</u> Direction <u>NW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd rock		112	117	17. Pump: <u>Not installed</u> Manufacturer's name <u>Simmons</u> Model number <u>US</u> HP <u>30</u> Volts <u>460</u> Length of drop pipe <u>195</u> ft. capacity <u>430</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd coarse		137	157	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name License No. Address <u>Sept City, KS 67871</u> Signature <u>[Signature]</u> Date <u>7-19-76</u> Authorized representative		
Clay		157	168			
Sd coarse		168	179			
Clay		179	185			
Sd coarse		185	188			
Clay		188	195			
18. Elevation:		19. Remarks:		21. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Sd coarse Clay yellow Shale		22. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name License No. Address <u>Sept City, KS 67871</u> Signature <u>[Signature]</u> Date <u>7-19-76</u> Authorized representative		
		195	203			
		203	210			
		210				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5