


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

SHARON SPRINGS 4SE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Wichita	Fraction SE 1/4 NW 1/4 SW 1/4	Section number 4	Township number T 18 S R 38	Range number EM
2. Distance and direction from nearest town or city:	2 1/4 N, 1/4 E of Selkirk, Kansas		3. Owner of well: R.R. or street: City, state, zip code:	Wayne Marcy Box 216 Leoti, KS 67861	
4. Locate with "X" in section below:	Sketch map:		<p>Xwell  ↓ 200' Septet </p>		
			6. Bore hole dia. 9 in. Completion date 2-9-77 Well depth 212 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Plas Height: above or below Threaded <input type="checkbox"/> Welded Glue Surface 12 in. RMP X PVC Weight 1.8 lbs./ft. Dia. 5 in. to 192 in. depth Wall Thickness: inches or Dia. 5 in. to 212 ft. depth gage No. 250		
			10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5 in. <input checked="" type="checkbox"/> gauze 1/16 Length 20 ft. Set between 192 ft. and 212 ft. Gravel pack? yes Size range of material 1/4-1/8		
			11. Static water level: 145 ft. below land surface Date 2-7-77		
			12. Pumping level below land surfaces: 155 ft. after 1 hrs. pumping 10 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 10 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: X Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
			16. Nearest source of possible contamination: ft. 200 Direction South Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number EJ HP 1 Volts 220 Length of drop pipe 196 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			18. Elevation:	19. Remarks: Sd coarse Yellow	
				Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley BROOK 20' 7440 (TOP)	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name Scent Cnty. KS 67871 License No. Address 1000 S. Main St. Signed John Weishaar Date 3-7-77 Authorized representative John Weishaar Date 3-7-77	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WYC-5