

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Wichita	NE 1/4 NE 1/4 SE 1/4	14	T 18	S R 38 E
2. Distance and direction from nearest town or city:	6W, $\frac{1}{2}$ N, 300°W	3. Owner of well:	Frank Whitham		
Street address of well location if in city:	of Leoti, KS	R.R. or street:	Box Q		
4. Locate with "X" in section below:	Sketch map:	Xwell Feedlot Septic 1/2 mi.			
		6. Bore hole dia. <u>26</u> in. Completion date <u>10-26-74</u> Well depth <u>181</u> ft.			
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
		9. Casing: Material <u>Steel</u> Height: <u>Above</u> or <u>below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <u>16</u> ft. PVC <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>181</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>181</u> ft. depth gage No. <u>188</u>			
		10. Screen: Manufacturer's name <u>Free Flow</u> Type <u>Prime Steel</u> Dia. <u>16</u> in. Slot gauze <u>.125</u> Length <u>30</u> ft. Set between <u>151</u> ft. and <u>181</u> ft. ft. and <u>181</u> ft. Gravel pack? <u>yes</u> Size range of material <u>5/8-1</u>			
		11. Static water level: <u>128</u> ft. below land surface Date <u>8-27-74</u> mo./day/yr.			
		12. Pumping level below land surfaces: <u>162</u> ft. after <u>4</u> hrs. pumping <u>630</u> g.p.m. <u>167</u> ft. after <u>4</u> hrs. pumping <u>660</u> g.p.m. Estimated maximum yield <u>660</u> g.p.m.			
		13. Water sample submitted: <u>no</u> Yes <input checked="" type="checkbox"/> No Date <u>8-27-74</u>			
		14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade			
		15. Well grouted? <u>Y</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.			
		16. Nearest source of possible contamination: <u>Feed</u> ft. <u>2640</u> Direction <u>SW</u> Type <u>Lot</u> Well disinfected upon completion? <u>X</u> Yes <u>No</u>			
		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>US</u> HP <u>30</u> Volts <u>460</u> Length of drop pipe <u>170</u> ft. capacity <u>660</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		18. Elevation: <u>181</u> 19. Remarks: <u>Shale</u>			
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name <u>Scott City, KS 67871</u> License No. Address <u>Scott City, KS 67871</u> Signed <u>John Weishaar</u> Date <u>7-17-76</u> Authorized representative <u>John Weishaar</u> Date <u>7-17-76</u>			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5