

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

SHARON SPRINGS 4SW

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BCD

1. Location of well:		County Greeley	Fraction SE 1/4 SW 1/4 NW 1/4	Section number 7	Township number T 18 S R 39	Range number 39
2. Distance and direction from nearest town or city: 4N, 1/2 E, 1/2 S of Street address of well location if in city: Whitelaw, Kansas			3. Owner of well: Robt. Brunswig R.R. or street: City, state, zip code: Tribune, KS 67879			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: FEED LOT 1 1/2 mi. X WELL		6. Bore hole dia. 24 in. Completion date _____ Well depth 151 ft. 6-13-77		
5. Type and color of material		From		To		7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary
Clay		0		19		8. Use: _____ Domestic _____ Public supply _____ Industry <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other
Gyp		19		49		9. Casing: Material Steel Height Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 17.5 lbs./ft. Dia. 12 in. to 151 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 134
Clay		49		58		10. Screen: Manufacturer's name _____ Johnson Type Galv. Steel Dia. 12 in. Slot gauge 100 Length 20 ft. Set between 131 ft. and 151 ft. _____ ft. and _____ ft. Gravel pack <input checked="" type="checkbox"/> yes Size range of material 5/8-1/4 in.
Sd rock H		58		60		11. Static water level: _____ mo./day/yr. 115 ft. below land surface Date 5-4-77
Clay		60		71		12. Pumping level below land surfaces: 140 ft. after 8 hrs. pumping 180 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 180 g.p.m.
Sdy clay		71		92		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
Sd 'coarse'		92		101		14. Well head completion: _____ Pitless adapter _____ Inches above grade
Clay		101		108		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete Depth: From 0 ft. to 10 ft.
Clay		110		115		16. Nearest source of possible contamination: Feed Lot ft. 2640 Direction North Type Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No
Fine sd clay		115		130		17. Pump: _____ Not installed Manufacturer's name Could's Model number Uh66LM34 HP 10 Volts 460 Length of drop pipe 141 ft. capacity 180 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other
Sd coarse		130		135		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address Sec 10, C 14, KS 67871 Signature _____ Date 7-12-77 Authorized representative
Clay		135		140		
Sd coarse		140		142		
Clay yellow		142		153		
Shale		153		155		
18. Elevation:		19. Remarks: BROCK 142' 3560 (TOP)				
Topography: _____ Hill <input checked="" type="checkbox"/> Slope _____ Upland _____ Valley						

18 39 E
R
7 SE SW NW
1/4 1/4 1/4