

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County McPherson	Fraction W/2 NE 1/4 SW 1/4	Section number 6	Township number T 18 S	Range number R 4 NW
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Lucile Johnson R.R. or street: 523 W. KANSAS City, state, zip code: McPherson, Kans		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. 3.0 in. Completion date 1-15-76 Well depth 60 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Trinit Weight: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 92 lbs./ft. Dia. 16 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 3/4"		
			10. Screen: Manufacturer's name AUGORA TILE CO Type TRAVITE Dia. 16" I.P. Slot/gauze 1/8 Length 26 ft Set between 37 ft. and 60 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4/4"		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 20 ft. below land surface Date 1-16-76		
			12. Pumping level below land surfaces: 51 ft. after 2 hrs. pumping 800 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 800 g.p.m.		
13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>					
14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade					
15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: ft. 2000 Direction no Type Well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: Not installed Manufacturer's name Western Pump Co Model number 617 HP 40 Volts <input type="checkbox"/> Length of drop pipe 57 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:			19. Remarks: Valley		
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Peterson Bruce M 138 Business name License No. Address Box 150 Lyndburg, Ks Signed William Peterson Date 4-13-76 Authorized representative 21					

18 - 40 - 6 W/2 NE 1/4 SW