


TRIBUNE

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BAA

1. Location of well:		County Greeley	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 29	Township number T 18 S R 40 E W	Range number
2. Distance and direction from nearest town or city: 1/4 SW of Tribune, KS			3. Owner of well: John Floyd R.R. or street: Tribune, KS 67879 City, state, zip code:			
4. Locate with "X" in section below: 			Sketch map: 1300' xwell			
5. Type and color of material			From	To	6. Bore hole dia. 9 in. Completion date 12-10-75 Well depth 117 ft.	
Clay			0	20	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Gyp			20	45	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sd rock			45	52	9. Casing: Material Plas Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Glue Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.8 lbs./ft. Dia. 5 in. to 97 ft. depth Wall Thickness: inches or Dia. 5 in. to 97 ft. depth gage No. 250	
Sd coarse			52	68	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5 in. <input checked="" type="checkbox"/> gauze 1/16 Length 20 ft. Set between 97 ft. and 117 ft. ft. and 117 ft. Gravel pack? Yes Size range of material 1/2-1/8	
Sd rock			68	71	11. Static water level: 102 ft. below land surface Date 12-10-75 mo./day/yr.	
Clay			71	73	12. Pumping level below land surfaces: NA ft. after NA hrs. pumping NA g.p.m. ft. after NA hrs. pumping NA g.p.m. Estimated maximum yield NA g.p.m.	
Sd coarse			73	82	13. Water sample submitted: NA mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
Sd rock			82	85	14. Well head completion: NA <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Sd coarse			85	95	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.	
Fine sd clay			95	100	16. Nearest source of possible contamination: Feed ft. 1300 Direction W Type Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Sd coarse T			100	108	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Weihsaar Drilling 232 Model number 232 HP 232 Volts 232 Length of drop pipe 232 ft. capacity 232 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay			108	110	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weihsaar Drilling 232 Business name Weihsaar Drilling License No. 232 Address 232 City, KS 67871 Signed Weihsaar Drilling Date 12-10-75 Authorized representative	
Sd coarse T			110	117		
Clay yellow			117			
BROCK 117						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: Do not know well head completion, since well not finished by us. 3622 (TUPO)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weihsaar Drilling 232 Business name Weihsaar Drilling License No. 232 Address 232 City, KS 67871 Signed Weihsaar Drilling Date 12-10-75 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						