

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number	
County: McPherson		SW 1/4 NW 1/4 NW 1/4		32		T 19 S		R 1 E/W	
Distance and direction from nearest town or city? 4 E 60194 1 1/4 So					Street address of well if located within city?				

2 WATER WELL OWNER:
 RR#, St. Address, Box # : **Blackstone Drilling Co.**
 City, State, ZIP Code : **Box 1184, McPherson, Kansas 67460**
 Board of Agriculture, Division of Water Resources
 Application Number:

3 DEPTH OF COMPLETED WELL: 90 ft. Bore Hole Diameter: 6 in. to 0 ft., and 90 in. to ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 7 Lawn and garden only 9 Dewatering 12 Other (Specify below)
 10 Observation well
 Well's static water level: 30 ft. below land surface measured on 1 month 30 day 80 year
 Pump Test Data: Well water was 35 ft. after 1 hours pumping 50 gpm
 Est. Yield gpm: Well water was ft. after hours pumping gpm

4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
 7 Fiberglass Threaded
 Blank casing dia 3 in. to 0 ft., Dia 70 in. to ft., Dia 70 in. to ft.
 Casing height above land surface 18 in., weight 160 lbs./ft. Wall thickness or gauge No 231
TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)
 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify)
 Screen-Perforated Dia 3 in. to 70 ft., Dia 90 in. to ft., Dia 90 in. to ft.
 Screen-Perforated Intervals: From 70 ft. to 90 ft., From ft. to ft., From ft. to ft.
 Gravel Pack Intervals: From 10 ft. to 90 ft., From ft. to ft., From ft. to ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From 0 ft. to 10 ft., From ft. to ft., From ft. to ft.
 What is the nearest source of possible contamination?
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
 13 Watertight sewer lines
 Direction from well 150 How many feet North ? Water Well Disinfected? Yes No X
 Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample was submitted month day year: Pump Installed? Yes No
 If Yes: Pump Manufacturer's name Model No. HP Volts
 Depth of Pump Intake ft. Pumps Capacity rated at gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on Jan. month 30 day 1980 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 134
 This Water Well Record was completed on Jan. month 31 day 1980 year under the business name of **Rosencrantz Bemis Ent. Inc.** by (signature) **Mike Davis**

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO		LITHOLOGIC LOG	FROM TO		LITHOLOGIC LOG
		0	30	Clay			
		30	34	Sand and Clay			
		34	38	Sand			
		38	45	Clay			
		45	53	Clay			
		53	60	Sand			
		60	87	Sand			
		87	90	Green Clay			

ELEVATION:

Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.