


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County McPherson	Fraction C 1/4 SE 1/4 NE 1/4	Section number 34	Township number T 24 S	Range number R 1 E
2. Distance and direction from nearest town or city: 1 1/2 S 1/4 1/2 S from Canton, Kansas Street address of well location if in city:		3. Owner of well: B & N Drilling Co. R.R. or street: Box 846 City, state, zip code: Independence, Kansas 67301				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 11 in. Completion date 8-12-78 Well depth 75 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other
top soil		0		3		9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 45 lbs./ft. Dia. 4 1/2 in. to 75 ft. depth Wall Thickness: inches or Dia. 4 1/2 in. to 75 ft. depth gage No. 1237
clay		3		16		10. Screen: Manufacturer's name CertainTeed Type PVC Dia. 40 Slot/gauge 1/16 Length 40 Set between 30 ft. and 70 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8
sand & gravel		16		20		11. Static water level: 20 ft. below land surface Date 8-12-78
clay		20		21		12. Pumping level below land surfaces: 20 ft. after 1 hrs. pumping 60 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 120 g.p.m.
sand & gravel		21		26		13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
clay		26		27		14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
sand & gravel		27		31		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
clay		31		47		16. Nearest source of possible contamination: ft. 120 Direction SW Type a/well Well disinfected upon completion? HTH Yes <input type="checkbox"/> No <input type="checkbox"/>
sandy clay		47		60		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
clay		60		70		18. Elevation:
 		 		 		19. Remarks:
 		 		 		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Basen Crantz Bemis 134 Business name Great Bend, Ks. 67530 Address License No. Signed Sandy Kilgore Date 9-13-78 Authorized representative