

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Rice	Fraction cs 1/4 se 1/4 se 1/4	Section number 4	Township number T 19 S R 10	Range number 10	(W)
2. Distance and direction from nearest town or city: 4 W 5 N 2 1/2 W from Lyons, Ks. Street address of well location if in city: Chase				3. Owner of well: Carl Steinert R.R. or street: none City, state, zip code: Chase, Kansas 67524			
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 11 in. Completion date _____ Well depth 135 ft. 6-5-79			
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material				9. Casing: Material pvc Height: Above or below _____ Threaded _____ Welded _____ Surface 24 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 1/2 in. to 135 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .258			
				10. Screen: Manufacturer's name CertainFeed Type pvc Dia. _____ Slot max 1/16 Length 20 Set between 115 ft. and 135 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material: 3/4 3/8			
				11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 6-4-79			
				12. Pumping level below land surfaces: 70 ft. after 1 1/2 hrs. pumping 40 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 6-4-79			
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
				16. Nearest source of possible contamination: ft. 120 Direction n Type hog pen Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed Sandy Tulgore Date 6-15-79 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

T 19
 R 10
 W
 E
 Sec 4
 CS 5555
 1/4 1/4 6 1/4