

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County: Barton		Fraction: 1/4 CNW 1/4 NW 1/4		Section number: 10		Township number: T 19 S R 11 E/W		Range number: 11	
2. Distance and direction from nearest town or city: 7 miles NE of Ellinwood, KS Street address of well location if in city:					3. Owner of well: Larry Klepper R.R. or street: 114 Craig City, state, zip code: Ellinwood, KS 67526				
4. Locate with "X" in section below: N 1 Mile W 1 Mile E S 1 Mile NW SW X NE SE NE SE					6. Bore hole dia. <u>9</u> in. Completion date <u>6-22-79</u> Well depth <u>45</u> ft. Pump Set <u>6-27-79</u>				
					7. ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary				
5. Type and color of material					8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other				
					9. Casing: Material <u>Styrene</u> Height: <u>Above</u> or below Threaded ☐ Welded ☒ Surface <u>12</u> in. RMP ☐ PVC ☐ Weight <u>1.5</u> lbs./ft. Dia. <u>5</u> in. to <u>30</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>45</u> ft. depth Gauge No. <u>200</u>				
Black Top Soil					10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>Styrene 200</u> Dia. <u>5"</u> <u>Slot</u> gauze <u>1/8"</u> Length <u>6'</u> Set between <u>30</u> ft. and <u>36</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>3/8-200</u>				
					11. Static water level: <u>24' 10"</u> mo./day/yr. <u>6-22-79</u> <u>ft. below land surface</u> Date				
Brown sandy clay					12. Pumping level below land surfaces: <u>N/C</u> <u>ft. after</u> <u>hrs. pumping</u> <u>g.p.m.</u> <u>ft. after</u> <u>hrs. pumping</u> <u>g.p.m.</u> Estimated maximum yield <u>g.p.m.</u>				
					13. Water sample submitted: <u>mo./day/yr.</u> <u>Yes</u> ☒ <u>No</u> Date				
Sand & Gravel					14. Well head completion: <u>12</u> Inches above grade <u>Pitless adapter</u>				
					15. Well grouted? <u>Yes</u> With: ☒ Neat cement ☐ Bentonite ☐ Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.				
Brown sandy clay					16. Nearest source of possible contamination: <u>XXX FIE</u> <u>ft.</u> Direction <u>Type</u> Well disinfected upon completion? ☒ Yes ☐ No				
					17. Pump: <u>Not installed</u> Manufacturer's name <u>Berkeley Pump Co.</u> Model number <u>4BL-12</u> HP <u>3/4</u> Volts <u>230</u> Length of drop pipe <u>35</u> ft. capacity <u>15</u> g.p.m. Type: ☒ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other				
18. Elevation:					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address <u>Great Bend, KS 67530</u> Signed <u>[Signature]</u> Date <u>6-29-</u> Authorized representative				
19. Remarks:									

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5