


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Barton	Township name Great Bend	Fraction SW of NW$\frac{1}{4}$	Section number 8	Town number T19S	Range number R12W
Distance and direction from nearest town or city: 3 mi. North of Great Bend, Kansas Street address of well location if in city:			3 Owner of well: Clarence Johnson Address: Great Bend, KS 67530			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 40 ft. Date of completion 8-18-75 Well diameter 9 in.
2 Type and color of material			From	To	5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary	
Top soil			0	3	6 Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐	
Brown & gray clay			3	29	7 Casing: Material Styrene Height: (above/below) Threaded ☐ Welded ☒ Surface 12 in. Diam. 5 in. to 30 ft. depth Drive shoe? ☐ Yes ☒ No 5 in. to 30 ft. depth	
Sand & gravel			29	40	8 Screen: Manufacturer Jess & Lowell Type Styrene 200 Dia. 5 " Slot/gauze 1/8 Length 10 ' Set between 30 ft. and 40 ft. Fittings: 3/8 -200 Gravel pack ☒ Yes ☐ No Size range of material	
					9 Static water level: 19 ft. below land surface Date 8-18-75	
					10 Pumping level below land surfaces: N/C ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					11 Water sample submitted: ☐ Yes ☒ No Date	
					12 Well head completion: ☐ Pitless adapter 12 inches above grade	
					13 Well grouted? ☒ Yes ☐ No ☒ Neat cement ☐ Bentonite ☐ Depth: From 0 ft. to 10 ft.	
					14 Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? ☒ Yes ☐ No	
					15 Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other	
16 Remarks: elevation Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley 1843			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address Great Bend, KS Signed C.W. Clarke Date 8-18-75 Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5