


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Barton	Fraction SW 1/4 Sec 24 T19S R13E	Section number 24	Township number T 19 S	Range number R 13 E
2. Distance and direction from nearest town or city: 2 miles south, 1/2 north		3. Owner of well: L O Drilling			
Street address of well location if in city: Great Bend		City, state, zip code: Great Bend Kan			
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 4 1/2 in. Completion date 3-17-78 Well depth 46 ft.	
5. Type and color of material		From	To	7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary	
				8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☒ Oil field water ☐ Other	
				9. Casing: Material ☒ Height: Above or below Threaded ☐ Welded ☐ Surface 17 in. RMP ☐ PVC ☒ Weight 206 lbs./ft. Dia. 4 in. to 4 1/2 in. depth Wall Thickness: inches or Dia. ☐ in. to ☐ ft. depth gage No. SEN 40	
				10. Screen: Manufacturer's name Shop Made Type Sand Dia. 4 Slot/gauze 1/8 Length 10 Set between 30 ft. and 40 ft. Gravel pack? ☒ Size range of material 4	
				11. Static water level: 10 ft. below land surface Date 3-17-78	
(Use a second sheet if needed)				12. Pumping level below land surfaces: 10 ft. after 1 hrs. pumping 100 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 175 g.p.m.	
				13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____	
				14. Well head completion: ____ Pitless adapter 12 inches above grade	
				15. Well grouted? ☒ With: ____ Neat cement ☒ Bentonite ____ Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? ____ Yes ____ No	
18. Elevation:				17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other	
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Myers Water Well Service Business name Great Bend Kan License No. 4453 Address Great Bend Kan Signed Thom G. Myers Date 3-31-78 Authorized representative			
		19. Remarks: 175 g.p.m.			
		Topography: ☐ Hill ☒ Slope ☐ Upland ☐ Valley			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5