USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Barton	C 1/4 NW 1/4 SW 1/4	31	T 19 S	R 13 E (W)

2. Distance and direction from nearest town or city:
[redacted] ½ mile South of Great Bend, KS
Street address of well location if in city:

3. Owner of well: Corregan Plumbing & Heating
R.R. or street: Box 1127
City, state, zip code: Great Bend, KS 67530

4. Locate with "X" in section below: Sketch map:

N — NW — NE — W — E — X — SW — SE — S — 1 Mile — 1 Mile

6. Bore hole dia. 9 in. Completion date 10-4-78
Well depth 60 ft. Pump Set 10-13-78

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material Styrene Weight: Above or below
Threaded ___ Welded X Surface 12 in.
RMP ___ PVC ___ Weight 1.5 lbs./ft.
Dia. 5 in. to 50 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 200

5. Type and color of material	From	To
Top soil	0	3
Brown clay	3	7
Sand & gravel	7	25
Brown & yellow clay	25	44
Sand & gravel	44	60

(Use a second sheet if needed)

10. Screen: Manufacturer's name Jess & Lowell
Type Styrene 200 Dia. 5"
Slot gauze 1/8" Length 10'
Set between 50 ft. and 60 ft.
___ ft. and ___ ft.
Gravel pack? Yes Size range of material 3/8-200

11. Static water level: mo./day/yr.
13 ft. below land surface Date 10-4-78

12. Pumping level below land surface: Not Checked
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date ___

14. Well head completion:
__ Pitless adapter 12 Inches above grade

15. Well grouted? Yes
With: X Neat cement ___ Bentonite ___ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: FIELD
ft. ___ Direction ___ Type ___
Well disinfected upon completion? X Yes ___ No

17. Pump: __ Not installed
Manufacturer's name Berkeley Pump Co
Model number 4BL-12 HP 3/4 Volts 230
Length of drop pipe 42 ft. capacity 15 g.p.m.
Type:
X Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

18. Elevation:
Topography:
__ Hill
__ Slope
__ Upland
__ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Clarke Well & Eq., Inc. 185
Business name License No.
Address Great Bend, KS 67530
Signed [signature] Date 10-17-78
Authorized representative

T 19 R 13 E (W) Sec 31 1/4 1/4 1/4 1/4 C NW SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023