

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Barton	Fraction C 1/4 1/2 1/4 NW 1/4	Section number 36	Township number T 19 S R 13 E/W	Range number
2. Distance and direction from nearest town or city: 1 1/2 mi. East of Great Bend, Kansas Street address of well location if in city:			3. Owner of well: Matthews Construction Co., Inc. R.R. or street: Rt. #3 City, state, zip code: Great Bend, Kansas 67530			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 7/8 . Completion date _____ Well depth: 60 ft. 4-4-78		
				7. ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
				8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☒ Lawn ☐ Oil field water ☐ Other		
5. Type and color of material!		From		To		9. Casing: Material pvc Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC ☒ Weight _____ lbs./ft. Dia. 5 1/2 in. to 60 ft. depth Wall thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .258
						10. Screen: Manufacturer's name _____ Type pvc Dia. 5 1/2 Slot/g. 1/32 Length 20 Set between 40 ft. and 60 ft. Gravel pack? ☒ Size range of material 3/4 3/8
Top soil		0		3		11. Static water level: _____ mo./day/yr. 14 ft. below land surface Date 4-4-78
Clay		3		5		12. Pumping level below land surfaces: 14 ft. after 1 hrs. pumping 120 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 300 g.p.m.
Gravel		5		29		13. Water sample submitted: _____ mo./day/yr. Yes ☐ No ☒ Date _____
Clay		29		34		14. Well head completion: ☐ Pitless adapter _____ inches above grade
Good sand & gravel		34		60		15. Well grouted? ☒ With: ☒ Neat cement ☐ Bentonite ☐ Concrete Depth: From 0 ft. to 16 ft.
						16. Nearest source of possible contamination: ft. 375 Direction WEST Type septic Well disinfected upon completion? HTH Yes ☐ No ☐
						17. Pump: ☒ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Kansas 67530 Signed Andy Kilgore Date 4-6-78 Authorized representative
18. Elevation:		19. Remarks:				
Topography: ☐ Hill ☐ Slope ☐ Upland ☒ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5