

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Barton</u>	Fraction <u>1/4</u> <u>1/4</u> <u>CSE</u> <u>4</u>	Section number <u>5</u>	Township number T <u>19</u> S R <u>14</u> <u>W</u>	Range number <u>14</u> <u>W</u>
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>Heizer, KS</u>			3. Owner of well: <u>Roy Biles</u> R.R. or street: <u>R 4</u> City, state, zip code: <u>Great Bend, KS</u>			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 			6. Bore hole dia. <u>8</u> in. Completion date <u>6-6-77</u> Well depth <u>55</u> ft.			
5. Type and color of material			7. <u>X</u> Cable tool <u>X</u> Rotary <u> </u> Driven <u> </u> Dug <u> </u> Hollow rod <u> </u> Jetted <u> </u> Bored <u> </u> Reverse rotary			
			8. Use: <u>X</u> Domestic <u> </u> Public supply <u> </u> Industry <u> </u> Irrigation <u> </u> Air conditioning <u> </u> Stock <u> </u> Lawn <u> </u> Oil field water <u> </u> Other			
			9. Casing: Material <u> </u> Height: <u>Above</u> or below Threaded <u> </u> Welded <u> </u> Surface <u>12</u> in. RMP <u> </u> PVC <u>X</u> Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>5.5</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>Sch 40</u>			
			10. Screen: Manufacturer's name <u>MPI</u> Type <u>PVC</u> Dia. <u>5</u> Slot/gauze <u>1/16"</u> Length <u>15</u> Set between <u>40</u> ft. and <u>55</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>X</u> Size range of material <u>1/8-3/4"</u>			
			11. Static water level: <u>17</u> ft. below land surface Date <u>6-6-77</u> mo./day/yr.			
(Use a second sheet if needed)			12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>50</u> g.p.m.			
			13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u>X</u> No Date <u> </u>			
			14. Well head completion: <u> </u> Pitless adapter <u>12</u> Inches above grade			
			15. Well grouted? <u>X</u> With: <u>X</u> Neat cement <u> </u> Bentonite <u> </u> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
			16. Nearest source of possible contamination: <u>Septic</u> ft. <u>10</u> Direction <u>S</u> Type <u>TANK</u> Well disinfected upon completion? <u>X</u> Yes <u> </u> No			
18. Elevation:			17. Pump: <u>X</u> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other			
			19. Remarks: <u>The Sts are Not Named</u> <u>or Numbered in</u> <u>Heizer, KS.</u>			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>186</u> <u>Kellys Water Well Ser</u> Business name License No. <u> </u> Address <u>R2 Great Bend, KS</u> Signed <u>Kelly Price</u> Date <u>7-17-78</u> Authorized representative			
			Topography: <u> </u> Hill <u> </u> Slope <u> </u> Upland <u>X</u> Valley			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5