


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Barton	Township name Buffalo	Fraction SE 1/4 NW 1/4 SW 1/4	Section number 20	Town number T19S	Range number R14W
Distance and direction from nearest town or city: 6 mi. West of Great Bend, KS Street address of well location if in city:				3 Owner of well: Bob LeRoy Address: Great Bend, Kansas		
Locate with "X" in section below: 				Sketch map:		
2				4 Well depth: 56 ft. Date of completion 4-28-75 Well diameter 9 in.		
Type and color of material				From	To	5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary
Top soil				0	3	6 Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☒ Styrene
Brown & gray clay				3	33	7 Casing: Material XXXXX Height: above/below Threaded ☐ Welded ☒ Surface 12 in. Diam. 5 in. to 35 ft. depth Drive shoe? ☐ Yes ☒ No 5 in. to 35 ft. depth
Sand & gravel				33	43	8 Screen: Manufacturer Jess & Lowell Type Styrene 200 Dia. 5" Slot/gauze 1/8 Length 21' Set between 35 ft. and 56 ft. Fittings: Gravel pack ☒ Yes ☐ No Size range of material 3/8-200
Brown clay				43	47	9 Static water level: 12 ft. below land surface Date 4-28-75
Sand & gravel				47	56	10 Pumping level below land surfaces: N/C ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
BR ≥ 56'						11 Water sample submitted: ☐ Yes ☒ No Date ____
						12 Well head completion: ☐ Pitless adapter 12 inches above grade
						13 Well grouted? ☒ Yes ☐ No ☒ Neat cement ☐ Bentonite ☐ Depth: From 0 ft. to 10 ft.
						14 Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? ☒ Yes ☐ No
						15 Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other
(use a second sheet if needed)						
16 Remarks: elevation Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address Great Bend, KS Signed ____ Date 4-28-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5