

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 62a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Barton		Fraction 1/4 SW 1/4SW 1/4		Section number 29		Township number T 19 S R 14		Range number 14	
1. Location of well: 5 miles West of Great Bend Street address of well location if in city:				3. Owner of well: William Kuhn R.R. or street: 1307 Odell City, state, zip code: Great Bend, KS 67530					
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>2-17-78</u> Well depth <u>60</u> ft.			
5. Type and color of material				From		To		7. ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary	
								8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other	
Top soil				0		3		9. Casing: Material <u>Styrene</u> ☒ Above or below Threaded ☐ Welded ☒ Surface <u>12</u> in. RMP ☐ PVC ☐ Weight <u>1.5</u> lbs./ft. Dia. <u>5</u> in. to <u>50</u> ft. depth Wall thickness: inches or Dia. <u>5</u> in. to <u>50</u> ft. depth <u>1/2</u> in. No. <u>200</u>	
Brown clay				3		20		10. Screen: Manufacturer's name <u>Jess E Lowell</u> Type <u>Styrene 200</u> Dia. <u>5"</u> Slot gauze <u>1/8</u> Length <u>10'</u> Set between <u>50</u> ft. and <u>60</u> ft. Gravel pack? <u>yes</u> Size range of material <u>3/8-200</u>	
Sand & gravel				20		42		11. Static water level: <u>26' 6"</u> mo./day/yr. <u>2-17-78</u> ft. below land surface Date	
Brown clay				42		44		12. Pumping level below land surfaces: <u>Not Checked</u> ft. after _____ hrs. pumping _____ g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Sand & gravel				44		59		13. Water sample submitted: _____ mo./day/yr. Yes ☐ No ☒ Date _____	
Yellow clay				59		60		14. Well head completion: _____ Pitless adapter <u>12</u> inches above grade	
								15. Well grouted? <u>yes</u> With: ☒ Neat cement ☐ Bentonite ☐ Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
								16. Nearest source of possible contamination: <u>Field</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? ☒ Yes ☐ No	
								17. Pump: ☒ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other	
								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>185</u> Clarke Well & Equipment, Inc Business name _____ License No. _____ Address <u>Great Bend, KS 67530</u> Signed <u>C. W. Clarke</u> Date <u>2-20-78</u> Authorized representative	
18. Elevation:		19. Remarks:							
Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley									

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5