

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Timken

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Rush	Fraction C 1/4 NE 1/4 NE 1/4	Section number 12	Township number T 19	Range number S R 17	EW
2. Distance and direction from nearest town or city: 3-5 1/4 E of Timken, Ks Street address of well location if in city:			3. Owner of well: Ed Nather R.R. or street: None City, state, zip code: Timken, Ks.				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 1 1/2 in. Completion date Well depth 180 ft. 7-31-78		
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Top soil		0	3	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 30 in. to 180 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 258			
Clay		3	18	10. Screen: Manufacturer's name Certain Feed Type PVC Dia. _____ Slot/gauze 1/16 Length 30 Set between 150 ft. and 180 ft. _____ ft. and _____ ft.			
Shale		18	135	Gravel pack? <input checked="" type="checkbox"/> Size range of material 2m 3			
sand rock & shale		135	150	11. Static water level: _____ mo./day/yr. 100 ft. below land surface Date 7-31-78			
White clay		150	155	12. Pumping level below land surfaces: 125 ft. after 1 hrs. pumping 5 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.			
sand rock & shale		155	180	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 7-31-78			
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.			
				16. Nearest source of possible contamination: ft. 400 Direction NE Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrants-Bemis 134 Business name _____ license No. _____ Address Great Bend, Ks. 67530 Signed Sandy Helgare Date 8-1 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		2087 12 189					

19 170 12
T
R
Sec
Q
NE 1/4
1/4 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5