

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Rush	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 17	Township number T 19 S R	Range number 17 E W
2. Distance and direction from nearest town or city: 1 1/2 miles east 5 south 1 1/2 miles east Rush Center, Ks.				3. Owner of well: Leroy Schraeder R.R. or street: RR Rush Center, Ks. City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 11-16-79 Well depth 280 ft.		
		<p>7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 280 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 26</p>		10. Screen: Manufacturer's name Jet stream Type pvc Dia. 5 Slot size .031 Length 20 Set between 260 ft. and 280 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 to 3/8		
				5. Type and color of material		11. Static water level: 160 ft. below land surface Date 11-16-79 mo./day/yr.
		From	To	12. Pumping level below land surfaces: 172 ft. after 2 hrs. pumping 15 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15 g.p.m.		
topsoil		0	5	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
clay		5	47	14. Well head completion: 24 <input type="checkbox"/> Pitless adapter _____ Inches above grade		
shale		47	209	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 12 ft.		
white and red Dakota clay		209	254	16. Nearest source of possible contamination: ft. 150 Direction west Type barn Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
sandstone		254	280	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Well 199 Business name E. Hiway 40 Hays, KS. License No. _____ Address _____ Signed Thad Karst Date 11-16-79 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 19
 R 12
 Sec 17
 SE 1/4
 SW 1/4