

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Rush	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 24	Township number T 19 S R 17 E/W	Range number
2. Distance and direction from nearest town or city: Timkin			3. Owner of well: Don Baker			
Street address of well location if in city: 5 1/2 south, 2 east			R.R. or street: City, state, zip code: Timkin, Kansas 67582			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map:			6. Bore hole dia. 1 1/2 in. Completion date 8-30-79 Well depth 225 ft.
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
5. Type and color of material			From	To	9. Casing: Material PVC Height: Above or Below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 1/2 in. to 200 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .258	
top soil			0	3	10. Screen: Manufacturer's name certain teed Type PVC Dia. 5 1/2 Slot/gauze 1/16 Length 40 Set between 225 ft. and 185 ft. _____ ft. and _____ ft.	
clay			3	15	Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4-3/8-1/2	
rock			15	35	11. Static water level: _____ mo./day/yr. 145 ft. below land surface Date 6-13-79	
shale rock			35	47	12. Pumping level below land surfaces: 150 ft. after 1 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 80 g.p.m.	
shale			47	135	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 6-13-79	
white clay			135	140	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade	
sand, and rock clay			140	155	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.	
white clay			155	160	16. Nearest source of possible contamination: ft. 300 Direction NE Type septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
sand rock clay mixed			160	205	17. Pump: _____ Not installed Manufacturer's name Red Jacket Model number 14BC HP 1 Volts 230 Length of drop pipe 189 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other	
clay			205	208		
good clean sand rock			208	225		
shale			225			
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address BOX 713 Great Bend, KS Signed Frederic Pedersen Date 9/3/79 Authorized representative			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5