


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <u>McPherson</u>	Township name <u>McPherson</u>	Fraction <u>SW 1/4 SW 1/4</u>	Section number <u>7</u>	Town number <u>T 19 S</u>	Range number <u>R 3 W</u>
Distance and direction from nearest town or city: <u>1 N - 1 3/4 W</u>				3 Owner of well: <u>Clarence Landa</u>		
Street address of well location if in city: <u>McPherson</u>				Address: <u>McPherson, Mo.</u>		
Locate with "X" in section below: N  S 1 Mile				Sketch map:		
2 Type and color of material				4 Well depth: <u>130</u> ft. Date of completion <u>4-16-75</u> Well diameter <u>5"</u> in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material <u>PVC</u> Height <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>5"</u> in. to <u>12</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No <u>5</u> in. to <u>12</u> ft. depth		
				8 Screen: <u>Certain Lead</u> Manufacturer <u>PVC</u> Dia. <u>5"</u> Type <u>432</u> Length <u>10 ft</u> Slot/gauze <u>120</u> ft. and <u>120</u> ft. Set between <u>120</u> ft. and <u>120</u> ft. Fittings: <u>1/2" - 1/8"</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>---</u>		
				9 Static water level: <u>86</u> ft. below land surface Date <u>4-16-75</u>		
				10 Pumping level below land surfaces: <u>90</u> ft. after <u>2</u> hrs. pumping <u>15</u> g.p.m. <u>---</u> ft. after <u>---</u> hrs. pumping <u>---</u> g.p.m. Estimated maximum yield <u>40</u> g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>---</u>		
				12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12"</u> inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>5</u> ft. to <u>15</u> ft.		
				14 Nearest source of possible contamination: ft. <u>130</u> Direction <u>SW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>---</u> Model number <u>---</u> HP <u>---</u> Volts <u>---</u> Length of drop pipe <u>---</u> ft. capacity <u>---</u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation <u>1500</u> Topography: <u>1910</u> <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>B. Terson Bros INC</u> <u>138</u> Business name License No. Address <u>Box 150 Lindsborg, KAN</u> Signed <u>Walter Peterson</u> Date <u>4-17-75</u> Authorized representative		