


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County McPHERSON	Fraction NW NE SE SE	Section number 17	Township number T-19-S	Range number R-3-E
2. Distance and direction from nearest town or city: 1 mile Street address of well location if in city: 3/4 mile W. edge of McPherson		3. Owner of well: Abner Vickrey R.R. or street: 1128 E. Hulse City, state, zip code: McPherson Ks. 67460				
4. Locate with "X" in section below: 		Sketch map: 6. Bore hole dia. 8 in. Completion date 12-30-77 Well depth 150 ft. 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 1 1/2 lbs./ft. Dia. 4 in. to 4 ft. depth Wall Thickness: inches or Dia. 4 in. to 4 ft. depth gage No. 14				
5. Type and color of material		From	To	10. Screens Manufacturer's name Peerless Plastics Type PVC Dia. 4" Slot/gauze 1/32" Length 15' Set between 135 ft. and 150 ft. Gravel pack? Yes Size range of material 1/4"		
Top soil		0	5	11. Static water level: 95 ft. below land surface Date 12-30-77		
Pink clay		5	15	12. Pumping level below land surfaces: 100 ft. after 1 1/2 hrs. pumping 10 g.p.m. 100 ft. after 1 1/2 hrs. pumping 10 g.p.m. Estimated maximum yield 20 g.p.m.		
Grey clay		15	30	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 12-30-77		
Buff clay		30	45	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
Grey clay + very fine sand		45	60	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Buff clay + very fine sand		60	90	16. Nearest source of possible contamination: cattle ft. 2000 Direction East Type cattle Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Med + fine sand		90	105	17. Pump: <input checked="" type="checkbox"/> Not installed		
Buff clay		105	115	Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay + sand layers		115	135	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Peterson Irrigation 138A Business name _____ License No. _____ Address Box 150 Lindsborg Ks Signed Mike Chambers Date 1-11-78 Authorized representative		
Med. coarse sand + gravel		135	150			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

19-30-17 NW NE SE
R 1/4 1/4 1/4