


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County McPherson	Fraction SW 1/4 SE 1/4 NW 1/4	Section number 20	Township number T 19 S R 3	Range number AW
2. Distance and direction from nearest town or city: Street address of well location if in city:		1330 N. 81 By Pass McPherson, Ks.		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:				6. Bore hole dia. 8 in. Completion date Well depth 150 ft. 6-19-79		
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top Soil		0	9	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Buff Clay		9	39	9. Casing: Material <input type="checkbox"/> Height <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 98 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft.		
Gray Clay		39	44	Dia. 35 in. to 130 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 12514		
Buff Clay		44	94	10. Screens: Manufacturer's name Peerless Plastics		
FINE SAND		94	104	Type PVC Dia. 5"		
Gray Clay		104	107	Slot/gauze 1/16 Length 20		
MEDIUM SAND		107	151	Set between 130 ft. and 150 ft. ft. and ft.		
				Gravel pack? YES Size range of material 1/4 in.		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 86 ft. below land surface Date 6-19-79		
				12. Pumping level below land surfaces: 90 ft. after 2 hrs. pumping 20 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 35-50 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: Pitless adapter 18 Inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
				16. Nearest source of possible contamination: WATER ft. 250 Direction W Type AT Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON IRRIGATION 138 Business name License No. Address Box 150 LINCOLN, KS. Signed Mike Peterson Date 7-14-79 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						