


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County McPherson	Fraction NE 1/4 SE 1/4 SW 1/4	Section number 29	Township number T 19 S	Range number R 3 W	
2. Distance and direction from nearest town or city: 620 TWIN LAKE DR.		3. Owner of well: Quida Pyle				
Street address of well location if in city: McPherson, KS		R.R. or street: 620 TWIN LAKE DR.				
		City, state, zip code: McPherson, KS. 67460				
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 8 in. Completion date 10-26-78 Well depth 120 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top soil		0	5	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Buff clay		5	35	9. Casing: Material <input type="checkbox"/> Height: (Above) or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2 lbs./ft.		
Very fine sand + clay		35	60	Dia. 4 in. to 100 ft. depth Wall Thickness: inches or Dia. 4 in. to 100 ft. depth gage No. 25		
Med + fine sand		60	80	10. Screen: Manufacturer's name Peerless Plastics Type PVC Dia. 4" Slot/gauze 1/16 Length 20' Set between 100 ft. and 120 ft. ft. and 120 ft. Gravel pack? Yes Size range of material 1/4		
Hard clay		80	105	11. Static water level: 78 ft. below land surface Date 10/26/78 mo./day/yr.		
Med. coarse sand		105	120	12. Pumping level below land surfaces: 92 ft. after 2 hrs. pumping 15 g.p.m. ft. after 2 hrs. pumping 15 g.p.m. Estimated maximum yield 40 g.p.m.		
				13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 10/26/78 mo./day/yr.		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 150 Direction NW Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name MEYERS Model number SCR1531-154 HP 15 Volts 230 Length of drop pipe 100 ft. capacity 100 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON IRRIGATION 138 Business name License No. Address Box 150 Lincolnton, KS Signed Mike Peterson Date 11-17-78 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5