

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County McPherson	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 32	Township number T 19 S R 3	Range number 32
2. Distance and direction from nearest town or city: Southwest of City Street address of well location if in city:				3. Owner of well: City of McPherson R.R. or street: City Building City, state, zip code: McPherson, Kansas 67460		
4. Locate with "X" in section below: Sketch map: <p>Monitor Well No. 7-77</p>				6. Bore hole dia. 5 in. Completion date 3/17/77 Well depth 185 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 0.676 lbs./ft. Dia. 2 in. to 155 ft. depth Wall Thickness: inches or Dia. 0.154 in. to 155 ft. depth gage No. 0.154		
				10. Screen: Manufacturer's name Layne Type Slotted Dia. 4" Slot/gauze 0.100" Length 20' Set between 155 ft. and 175 ft. Gravel pack? yes Size range of material 1/8-1/4		
				11. Static water level: 72 ft. below land surface Date 3/17/77 12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 3/14/77				14. Well head completion: <input type="checkbox"/> Pitless adapter ____ inches above grade		
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				16. Nearest source of possible contamination: ** ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				18. Elevation: 1494+- Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
19. Remarks: ** Not determined				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name License No. Address Wichita, Kansas Signed [Signature] Date 4/5/77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5