

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 20	Township number T 19 S R 31	Range number 31	XXW
2. Distance and direction from nearest town or city: 6 miles E, 6 miles S, 2 1/2 miles E, south side of the road			3. Owner of well: Alva Dearden R.R. or street: RFD 1 City, state, zip code: Scott City, KS 67871				
4. Locate with "X" in section below:		Sketch map: County Road			6. Bore hole dia. 1 9/16 in. Completion date 6-12-78 Well depth 123 ft.		
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 103 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 0.265			
				10. Screen: Manufacturer's name Peerless Plastics Type PVC Dia. 5" Slot/gauze 0.060" Length 29 ft. Set between 104 ft. and 123 ft. _____ ft. and _____ ft. Gravel pack? no Size range of material _____			
				11. Static water level: _____ mo./day/yr. 75 ft. below land surface Date 6-10-78			
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			
				14. Well head completion: 12 inches above grade <input checked="" type="checkbox"/> Pitless adapter _____			
				15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.			
				16. Nearest source of possible contamination: ft. 65 Direction south Type Barn Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: Not installed Manufacturer's name Aermotor Model number SE 30- HP 300 Volts 230 Length of drop pipe 118 ft. capacity 35 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. ABC Drilling, Inc. 246 Business name License No. Address Scott City, KS 67871 Signed Sybil H. Ross Date 6-12-78 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

19 370 20 2000000
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5