

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 16	Township number T 19 S R	Range number 33
2. Distance and direction from nearest town or city: 6S, 3W, of				3. Owner of well: C. T. Hutchins		
Street address of well location if in city: Scott City, KS				R.R. or street: 1102 College		
				City, state, zip code: Scott City, KS 67871		
4. Locote with "X" in section below:		Sketch map:		6. Bore hole dia. <u>20</u> in. Completion date _____		
N		W		Well depth <u>140</u> ft. <u>6-3-75</u>		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
E		S		8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
1 Mile		1 Mile		9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below		
				Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>10</u> in.		
				RMP _____ PVC _____ Weight <u>31.67</u> lbs./ft.		
				Dia. <u>16</u> in. to <u>140</u> ft. depth Wall Thickness: inches or		
				Dia. _____ in. to _____ ft. depth gage No. <u>.188</u>		
5. Type and color of material		From	To	10. Screen: Manufacturer's name _____		
Clay		0	18	Type <u>Free Flow</u>		
Sd		18	22	Type <u>Prime Steel</u> Dia. <u>16 in.</u>		
Clay		22	65	Slo/gauze <u>.125</u> Length <u>40 ft.</u>		
Sand		65	90	Set between <u>100</u> ft. and <u>140</u> ft.		
Fine sd		90	99	_____ ft. and _____ ft.		
Sand		99	119	Gravel pack? <u>yes</u> Size range of material <u>3/4-1/2</u>		
Clay		119	126	11. Static water level: _____ mo./day/yr.		
Fine sd clay		126	135	<u>86</u> ft. below land surface Date <u>4-11-75</u>		
Clay yellow		135	139	12. Pumping level below land surfaces:		
Shale		139		<u>115</u> ft. after <u>4</u> hrs. pumping <u>450</u> g.p.m.		
				<u>118</u> ft. after <u>4</u> hrs. pumping <u>500</u> g.p.m.		
				Estimated maximum yield <u>500</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr.		
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion:		
				_____ Pitless adapter _____ Inches above grade		
				15. Well grouted? _____		
				With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____		
				Depth: From <u>0</u> ft. to <u>12</u> ft.		
				16. Nearest source of possible contamination: <u>Feed</u>		
				ft. <u>2640</u> Direction <u>W</u> Type <u>Lot</u>		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
				17. Pump: _____ Not installed		
				Manufacturer's name <u>Western Land Roller</u>		
				Model number _____ HP _____ Volts _____		
				Length of drop pipe <u>130</u> ft. capacity <u>500</u> g.p.m.		
				Type:		
				_____ Submersible _____ Turbine <input checked="" type="checkbox"/>		
				_____ Jet _____ Reciprocating _____		
				_____ Centrifugal _____ Other _____		
(Use a second sheet if needed)				20. Water well contractor's certification:		
18. Elevation:		19. Remarks:		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography:				<u>Weishaar Drilling</u> <u>232</u>		
_____ Hill				Business name _____ License No. _____		
_____ Slope				Address <u>Scott City, KS 67871</u>		
<input checked="" type="checkbox"/> Upland				Signed _____ Date _____		
_____ Valley				Authorized representative <u>7-19-76</u>		

T
P
M
L
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WW-C-5