

USE TYPEWRITER OR BALL POINT PEN - PRESS FIRMLY, PRINT CLEARLY.

SCOTT CITY

1933W23ABB

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment - Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ABB

1. Location of well:		County Scott	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 23	Township number T 19 S R 33	Range number 33
2. Distance and direction from nearest town or city: 5 1/2 S and 1 1/2 W of Scott City Street address of well location if in city:			3. Owner of well: Kirby Clawson R.R. or street: Satanta, KS 67870 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 26 in. Completion date _____ Well depth 194 ft. 2-17-77	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From			To	
See attachment						
BRUCK 192'						
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 194 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250	
					10. Screen: Manufacturer's name Johnson Type Continuous Dia. 16" Slot/gauze .100 Length 40' Set between 190-185 ft. and 170-160 ft. 150-140 ft. and 120-105 ft. Gravel pack? Yes Size range of material 1/4 x 1/8	
					11. Static water level: _____ mo./day/yr. 114 ft. below land surface Date 2-19-77	
					12. Pumping level below land surfaces: 160' ft. after _____ hrs. pumping 1248 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: _____ ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)				
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 2957 (0.00)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name License No. _____ Address Box 639 Garden City, KS Signed AA Pauchert Date 3-3-77 Authorized representative	

T 19 S R 33
 Sec 23
 NE NW SE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Kirby Clawson DATE 12-3-76
 STREET ADDRESS _____ TEST # 3 E. Log 200'
 CITY & STATE Satanta, KS DRILLER Rector
 COUNTY Scott QUARTER NE SECTION 23 TOWNSHIP 19 RANGE 33

LOCATION 150' E. of Test #1

%	DRILLED FOOTAGE		Description of Strata	WELL LOCATION
	From	Pay To		Static Water Level _____ Proposed Well Depth _____
	0		3	Surface
	3		43	Brown clay
	43		53	Sand fine med. coarse and small gravel
	53		60	Brown clay
	60		75	Sand fine med. coarse and med. small gravel, used lots of water
	75		80	Brown clay
	80		95	Fine sand and sandy clay
	95		100	Gray clay
50	100	20	120	Sand fine med. coarse, small gravel and tiny white rock, used lots of water
20	120	20	140	Gray clay and coarse sand sts.
70	140	12	152	Sand fine med. coarse, small gravel and small white rock, real loose, used lots of water
55	152	8	160	Fine sand, med. coarse, small coarse, few tiny white rock and small clay sts., loose, used water
30	160	12	172	Sand fine med. coarse, gray sandy clay
	172		186	Brown clay and fine sand
65	186	6	192	Sand fine med. coarse, med. small gravel and tiny white and tan rock, real loose, used lots of water
	192		193	Yellow clay
	193		200	Shale
		78		
				TOTAL DEPTH OF WELL 194 FT.
				Set up west
				Pit on north

GARDEN CITY, KANSAS
 PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
 IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
 PHONE 675-4311

TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****