

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.


SHALLOW WATER

1933W2SA
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 826-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ACC

1 Location of well:	County Scott	Township name Valley SW NW N/E	Fraction	Section number 25	Town number 19	Range number 33
Distance and direction from nearest town or city: Street address of well location if in city: Shallow Water, KS				3 Owner of well: David Duff Address: Shallow Water, KS		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		
2 Type and color of material				From	To	
Clay				0	28	
Fine sd clay				28	35	
Sd coarse				35	46	
Fine sdy clay				46	53	
Clay sdy				53	118	
Clay				118	135	
Sd coarse				135	138	
Fine sdy clay				138	160	
Clay				160	202	
Yellow				202	204	
Shale				204		
(use a second sheet if needed)						
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley 2949 (TOP)				4 Well depth: 204 ft. Date of completion 4-10-75 Well diameter 9 in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material Plas Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. Weight 1.8 lbs./ft. 5 in. to 164 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
				8 Screen: Manufacturer Jess & Lowell Type Plastic Dia. 5 Slot/gauze _____ Length _____ Set between 164 ft. and 204 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #1		
				9 Static water level: 83 ft. below land surface Date 4-10-75		
				10 Pumping level below land surfaces: 93 ft. after 1 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 15 ft.		
				14 Nearest source of possible contamination: ft. 300 Direction SE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Red Jacket Model number 150N1 HP 1 1/2 Volts 230 Length of drop pipe 159 ft. capacity 20 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed [Signature] Date 5-29-75 Authorized representative						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5