

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 28	Township number T 19 S R 34	Range number EW
2. Distance and direction from nearest town or city: 9W, 8S, 1/2W, 1/8N of Scott City, KS			3. Owner of well: Hattendorf Bros. Box 339 Scott City, KS 67871			
4. Locate with "X" in section below:			Sketch map:			
			<p>6. Bore hole dia. <u>9</u> in. Completion date <u>7-2-75</u> Well depth <u>155</u> ft.</p> <p>7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material <u>Plas. Glue</u> Height: <u>Above</u> or below Threading: <u>Welded</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>155</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>155</u> ft. depth gage No. <u>.250</u></p>			
5. Type and color of material		From	To			
Clay		0	20	10. Screen: Manufacturer's name <u>Jess & Lowell</u>		
Gyp		20	36	Type <u>RMP</u> Dia. <u>5 in.</u> <u>1/16</u> gauze Length <u>50 ft.</u>		
Finest sd T		36	68	Set between <u>105</u> ft. and <u>155</u> ft. ft. and <u>155</u> ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>1/2-1/8</u>		
Sd coarse		68	136	11. Static water level: <u>119</u> ft. below land surface Date <u>6-14-75</u> mo./day/yr.		
Fine sd clay		136	145	12. Pumping level below land surfaces: <u>144</u> ft. after <u>1</u> hrs. pumping <u>70</u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>70</u> g.p.m.		
Sd fine		145	151	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>		
Clay yellow		151	153	14. Well head completion: <input type="checkbox"/> Pitless adapter <u> </u> inches above grade		
Shale		153	155	<input checked="" type="checkbox"/> Well grouted? <u> </u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. <u>2500</u> Direction <u>NE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds</u> Model number <u>11TX50434</u> HP <u>5</u> Volts <u>440</u> Length of drop pipe <u>149</u> ft. capacity <u>70</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name <u>Scott City, KS 67871</u> License No. Address <u> </u> Signed <u> </u> Date <u>7-22-76</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

10
11
12
13
14
15
16
17
18
19
20

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5