

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 28	Township number T 19 S R 34	Range number 34
2. Distance and direction from nearest town or city: 9W, 8S, 3/4W of Street address of well location if in city: Scott City, KS				3. Owner of well: Hattendorf TERNSKY Bros. R.R. or street: Box 339 City, state, zip code: Scott City, KS 67871		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>7-2-75</u> Well depth <u>156</u> ft. 626-75		
		<p style="text-align: center;">Septic</p> <p style="text-align: center;">2000'</p> <p style="text-align: center;">X well</p>		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Plas.</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Glue Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>156</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>250</u>		
Clay		0	24	10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5 in.</u> <input checked="" type="checkbox"/> gauze <u>1/16</u> Length <u>50 ft.</u> Set between <u>106</u> ft. and <u>156</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/2-1/8</u>		
Gyp		24	40	11. Static water level: <u>103</u> ft. below land surface Date <u>6-13-75</u> mo./day/yr.		
Sdy clay		40	60	12. Pumping level below land surfaces: <u>145</u> ft. after <u>1</u> hrs. pumping <u>70</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>70</u> g.p.m.		
Sd coarse		60	110	13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
Sd rock		110	114	14. Well head completion: <input type="checkbox"/> Pitless adapter <u> </u> inches above grade		
Sd coarse		114	131	15. Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Clay		131	142	16. Nearest source of possible contamination: ft. <u>2000</u> Direction <u>NE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd rock		142	143	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds</u> Model number <u>UTX 50434</u> HP <u>5</u> Volts <u>440</u> Length of drop pipe <u>150</u> ft. capacity <u>70</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sdy clay fine		143	152	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling <u>232</u> Business name <u>Scott City, KS 67871</u> License No. <u> </u> Address <u> </u> Signed <u> </u> Date <u>7-22-76</u> Authorized Representative		
Shale		152	156			
18. Elevation:		19. Remarks:		<p style="text-align: center;">(Use a second sheet if needed)</p>		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

19 34 28 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5