

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 28	Township number T 19 S R 34 E	Range number 34
2. Distance and direction from nearest town or city: 9W, 8S, 1W				3. Owner of well: Hattendorf Bros.		
Street address of well location if in city: 1/8N of Scott City, KS				R.R. or street: Box 339		
				City, state, zip code: Scott City, KS 67871		
4. Locate with "X" in section below:		Sketch map:				
		<p style="text-align: center;">Septic</p> <p style="text-align: center;">↗ 4620'</p> <p style="text-align: center;">X well</p>				
5. Type and color of material		From	To	6. Bore hole dia. <u>9</u> in. Completion date _____ Well depth <u>150</u> ft. <u>8-25-75</u>		
Clay		0	15	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Gyp		15	35	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Med sd		35	40	9. Casing: Material <u>Plas. Glue</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>150</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250</u>		
Fine sd clay		40	60	10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5 in.</u> <input checked="" type="checkbox"/> Slotted gauze <u>1/16</u> Length <u>40 ft.</u> Set between <u>110</u> ft. and <u>150</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/2-1/8</u>		
Sd coarse		60	70	11. Static water level: _____ mo./day/yr. <u>115</u> ft. below land surface Date <u>8-19-75</u>		
Sd rock		70	75	12. Pumping level below land surfaces: <u>139</u> ft. after <u>1</u> hrs. pumping <u>70</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>70</u> g.p.m.		
Sd coarse		75	87	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Fine sd clay		87	100	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade <input checked="" type="checkbox"/> Well grouted? _____ With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Sd coarse		100	119	16. Nearest source of possible contamination: ft. <u>4620</u> Direction <u>NE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd rock		119	121	17. Pump: _____ Not installed Manufacturer's name <u>Goulds</u> Model number <u>UTX 50434</u> HP <u>5</u> Volts <u>440</u> Length of drop pipe <u>144</u> ft. capacity <u>70</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd coarse		121	129			
Clay		129	137			
Fine sd loose		137	141			
Sd rock		141	142			
Fine sd		142	145			
Clay yellow (Use a second sheet if needed)		145	150			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			<u>Weishaar Drilling</u> 232 Business name License No. Address <u>Scott City, KS 67871</u> Signed <u>[Signature]</u> Date <u>7-22-76</u> Authorized representative			

1-2
3-4
5-6
7-8
9-10
11-12
13-14
15-16
17-18
19-20

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5