

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction WSW 1/4 NW 1/4 SE 1/4	Section number 28	Township number T 19 S R 34	Range number 34
2. Distance and direction from nearest town or city: 9W, 7 1/2 S, 1/2 W, Street address of well location if in city: 1/8 S of Scott City, KS			3. Owner of well: Hattendorf Bros. R.R. or street: Box 339 City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>9</u> in. Completion date _____ Well depth <u>145</u> ft. <u>7-2-75</u>	
		<p style="text-align: center;">Septic</p> <p style="text-align: center;">1/8 mi.</p> <p style="text-align: center;">X well</p>			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material				From	To	9. Casing: Material <u>Plas</u> Height: <u>Above</u> or below Threading <u>Welded</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>145</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250</u>
Clay				0	27	10. Screen: Manufacturer's name Jess & Lowell Type <u>RMP</u> Dia. <u>5</u> in. <input checked="" type="checkbox"/> gauze <u>1/16</u> Length <u>30</u> ft. Set between <u>115</u> ft. and <u>145</u> ft. _____ ft. and _____ ft.
Gyp				27	35	Gravel pack? <input checked="" type="checkbox"/> <u>yes</u> Size range of material: <u>1/2-1/8</u>
Fine sd clay T				35	44	11. Static water level: _____ mo./day/yr. <u>114</u> ft. below land surface Date <u>6-21-76</u>
Sdy clay				44	62	12. Pumping level below land surfaces: <u>134</u> ft. after <u>1</u> hrs. pumping <u>70</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>70</u> g.p.m.
Sd coarse				62	77	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Sdy clay				77	81	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
Sd coarse				81	100	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Clay				100	102	16. Nearest source of possible contamination: ft. <u>660</u> Direction <u>NE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Clay				102	123	17. Pump: Not installed Manufacturer's name <u>Goulds</u> Model number <u>UTX 50434</u> HP <u>5</u> Volts <u>440</u> Length of drop pipe <u>139</u> ft. capacity <u>70</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Sd clay				123	127	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling <u>232</u> Business name _____ License No. _____ Address <u>Scott City, KS 67871</u> Signed <u>[Signature]</u> Date _____ Authorized representative <u>7-22-76</u>
Clay				127	130	
Fine sd				130	135	
Clay sdy				135	140	
Clay yellow				140	144	
Shale				144	145	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5