

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction NW 1/4 NE 1/4 SE 1/4	Section number 28	Township number T 19 S R 34 E	Range number 34
2. Distance and direction from nearest town or city: 9W, 7 1/2 S, 1/4 W of			3. Owner of well: Hattendorf Bros.			
Street address of well location if in city: Scott City, KS			R.R. or street: Box 339			
			City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 5 in. Completion date _____		
				Well depth 135 ft. 8-25-75		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	39	9. Casing: Material Plas. Height: Above or below Threaded _____ Welded Glue Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight 1.8 lbs./ft. Dia. 5 in. to 135 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 250		
Fine sd clay		39	57	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5 in. <input checked="" type="checkbox"/> gauze 1/16 Length 30 ft. Set between 105 ft. and 135 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/2-1/8		
Sd coarse		57	90	11. Static water level: _____ mo./day/yr. 107 ft. below land surface Date 8-18-75		
Sdy clay		90	93	12. Pumping level below land surfaces: 124 ft. after 1 hrs. pumping 70 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 70 g.p.m.		
Fine sd clay		93	102	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Fine sd		102	114	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Sd coarse		114	125	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Yellow		125	135	16. Nearest source of possible contamination: ft. 1320 Direction E Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name Goulds Model number UTX 50434 HP 5 Volts 440 Length of drop pipe 129 ft. capacity 70 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed [Signature] Date 7-22-76 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5