

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 28	Township number T 19 S R 34 E	Range number 34 E
2. Distance and direction from nearest town or city: 9W, 7 1/2 S, 1/2 W of			3. Owner of well: Hattendorf Bros.			
Street address of well location if in city: Scott City, KS			R.R. or street: Box 339			
			City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date _____		
				Well depth <u>137</u> ft. <u>8-25-75</u>		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	26	9. Casing: Material <u>Plas</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>glue</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>137</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250</u>		
Sd med		26	35	10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5 in.</u> <input checked="" type="checkbox"/> gauze <u>1/16</u> Length <u>30 ft.</u> Set between <u>107</u> ft. and <u>137</u> ft. Set between _____ ft. and _____ ft.		
Clay		35	41	Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/2-1/8</u> ft.		
Fine sd clay T		41	57	11. Static water level: _____ mo./day/yr. <u>109</u> ft. below land surface Date <u>8-15-75</u>		
Sd coarse		57	91	12. Pumping level below land surfaces: <u>126</u> ft. after <u>1</u> hrs. pumping <u>70</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>70</u> g.p.m.		
Sd rock		91	93	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Sd coarse		93	126	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Sdy clay		126	129	15. Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Fine sd clay		129	132	16. Nearest source of possible contamination: ft. <u>1980</u> Direction <u>E</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Yellow		132	137	17. Pump: _____ Not installed Manufacturer's name <u>Goulds</u> Model number <u>UTX 50434</u> HP <u>5</u> Volts <u>440</u> Length of drop pipe <u>131</u> ft. capacity <u>70</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name _____ License No. _____ Address: <u>Scott City, KS 67871</u> Signed: <u>[Signature]</u> Date _____ Authorized representative <u>7-22-76</u>		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5