

1 LOCATION OF WATER WELL
 County: Scott Fraction SE 1/4 SW 1/4 SW 1/4 Section Number 30 Township Number T 19 S Range Number R 34 E **(EW)**
 Distance and direction from nearest town or city? 2 Miles West Street address of well if located within city?
8 miles south of Modoc, Kansas

2 WATER WELL OWNER: Alvia Lehman
 RR#, St. Address, Box # : 909 Main Board of Agriculture, Division of Water Resources
 City, State, ZIP Code : Scott City, Kansas 67871 Application Number:

3 DEPTH OF COMPLETED WELL. 103 ft. Bore Hole Diameter 9 in. to 103 ft. and in. to ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
Stockwell
 Well's static water level 78 ft. below land surface measured on 6 month 3 day 1980 year
 Pump Test Data NA : Well water was ft. after hours pumping gpm
 Est. Yield gpm: Well water was ft. after hours pumping gpm

4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
 7 Fiberglass Threaded
 Blank casing dia 5 in. to 83 ft. Dia in. to ft. Dia in. to ft.
 Casing height above land surface 12 in., weight 1.8 lbs./ft. Wall thickness or gauge No. 250
 TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)
 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)
 Screen-Perforation Dia 5 in. to 103 ft. Dia in. to ft. Dia in. to ft.
 Screen-Perforated Intervals: From 83 ft. to 103 ft. From ft. to ft. From ft. to ft.
 Gravel Pack Intervals: From 70 ft. to 103 ft. From ft. to ft. From ft. to ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Drill ~~Block~~ Cuttings
 Grouted Intervals: From 10 ft. to 70 ft. From 0 ft. to 10 ft. From ft. to ft.
 What is the nearest source of possible contamination:
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
 Direction from well West. How many feet 1320? Water Well Disinfected? Yes No
 Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample
 was submitted month day year: Pump Installed? Yes No
 If Yes: Pump Manufacturer's name Model No. Cylinder HP Volts
 Depth of Pump Intake 99 ft. Pumps Capacity rated at 4 gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed (2) reconstructed, or (3) plugged under my jurisdiction and was
 completed on 6 month 5 day 1980 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 232
 This Water Well Record was completed on 6 month 5 day 1980 year under the business
 name of Weishaar Drilling & Supply Inc. by (signature) [Signature]

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	18	Clay	18	45	Sand & gravel
45	69	Sand	69	71	Clay
71	99	Sand	99	103	Clay

ELEVATION:
 Depth(s) Groundwater Encountered 1. 78 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY
T 19
R 34
SEC. 30
SE 1/4 SW 1/4 SW 1/4