

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 33	Township number T 19 S R 34 E NW	Range number
2. Distance and direction from nearest town or city: 9W, 8S, 1/2W, 1/8S			3. Owner of well: Hattendorf Bros.			
Street address of well location if in city: of Scott City, KS			R.R. or street: Box 339 City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>8-29-75</u> Well depth <u>147</u> ft.		
		<p style="text-align: center;">N</p> <p style="text-align: center;">NW NE</p> <p style="text-align: center;">W E</p> <p style="text-align: center;">SW SE</p> <p style="text-align: center;">S</p> <p style="text-align: center;">1 Mile</p>		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	21	9. Casing: Material <u>Plas. Glue</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>147</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>.250</u>		
Gyp		21	35	10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5 in.</u> Slot gauze <u>1/16</u> Length <u>40 ft.</u> Set between <u>107</u> ft. and <u>147</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>1/2-1/8</u>		
Sd rock		35	43	11. Static water level: <u>107</u> ft. below land surface Date <u>8-22-75</u> mo./day/yr.		
Med sd		43	55	12. Pumping level below land surfaces: <u>136</u> ft. after <u>1</u> hrs. pumping <u>70</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>70</u> g.p.m.		
Sd rock		55	63	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>		
Fine sd clay		63	78	14. Well head completion: <input type="checkbox"/> Pitless adapter <u> </u> inches above grade		
Sd coarse		78	96	<input checked="" type="checkbox"/> Well grouted? <u> </u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Sd rock		96	97	16. Nearest source of possible contamination: ft. <u>3960</u> Direction <u>NE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd coarse		97	125	17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds</u> Model number <u>51A50434</u> HP <u>5</u> Volts <u>440</u> Length of drop pipe <u>141</u> ft. capacity <u>20</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd rock		125	128	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address <u>Scott City, KS 67871</u> Signed <u>[Signature]</u> Date <u>7-22-76</u> Authorized representative		
Fine sd clay		128	131			
Clay		131	141			
Fine sd		141	145			
Sd rock		145	146			
Fine sd clay		146	148			
<input checked="" type="checkbox"/> Clay yellow (Use a second sheet if needed)		148	155			
18. Elevation:		19. Remarks: Shale		20. Water well contractor's certification: (continued)		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		155				

1
9
3
4
3
3
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5