


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Wichita	NE 1/4 NE 1/4 SE 1/4	1	T 19	S R 38 E
2. Distance and direction from nearest town or city:	5W, 3 1/2 S of	3. Owner of well:	Gary Krenzel		
Street address of well location if in city:	Leoti, Kansas	R.R. or street:	Box 29		
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. 9 in. Completion date _____ Well depth 177 ft. 7-19-76	
	 <i>well</i> ← 100' → <i>Septic</i>			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material	From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay	0	21	9. Casing: Material <input checked="" type="checkbox"/> Plas. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Glue Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.8 lbs./ft. Dia. 5 in. to 137 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
Rock H	21	27	10. Screen: Manufacturer's name <input checked="" type="checkbox"/> Jess & Lowell Type <input checked="" type="checkbox"/> RMP Dia. 5 in. <input checked="" type="checkbox"/> Mesh gauze 1/16 Length 40 ft. Set between 137 ft. and 177 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <input type="checkbox"/> 1/8		
Sdy clay T	27	48	11. Static water level: mo./day/yr. 110 ft. below land surface Date 7-15-76		
Sd coarse	48	62	12. Pumping level below land surfaces: 120 ft. after 1 hrs. pumping 18 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 18 g.p.m.		
Sd rock H	62	65	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Sd	65	67	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
Sd rock H	67	69	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
Sdy clay	69	75	16. Nearest source of possible contamination: ft. 100 Direction E Type <input checked="" type="checkbox"/> Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd rock H	75	80	17. Pump: Not installed Manufacturer's name <input checked="" type="checkbox"/> Red Jacket Model number 200T1 HP 2 Volts 220 Length of drop pipe 170 ft. capacity 18 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sdy clay	80	117	18. Elevation: 19. Remarks: Sd med good 165 173 Clay yellow 173 180 Shale 180		
Clay	117	120	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Weishaar Drilling</i> 232 Business name <input checked="" type="checkbox"/> Scott City, KS 67871 License No. Address <input type="checkbox"/> Street <input type="checkbox"/> Authorize Date Signature <input type="checkbox"/> Authorized representative 8-17-76		
Fine sd clay	125	139			
Sd fine med	139	145			
Clay	145	162			
Fine sd clay	162	165			
Topography:					
<input type="checkbox"/> Hill					
<input type="checkbox"/> Slope					
<input checked="" type="checkbox"/> Upland					
<input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5