

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

LEOTI SW

_____ T R EW sec 1/4 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

DCO

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Wichita	Whiteman SW	SW- SE $\frac{1}{4}$	36	19	38
Distance and direction from nearest town or city:			5W, 9S, $\frac{1}{2}$ W of Leoti, KS	3 Owner of well:	Ed Dierks	
Street address of well location if in city:			Address: Leoti, KS 67861			
Locate with "X" in section below:			Sketch map:		4 Well depth: 150 ft. Date of completion 6-24-75 Well diameter 9 in.	
					<input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					5 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
					6 Casing: Material <u>Plas.</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 12 in. Weight 1.8 lbs./ft. 5 in. to 120 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth	
					7 Screen: Manufacturer <u>Jess & Lowell</u> Type <u>Plastic</u> Dia. 5 Slot/gauze Length Set between 120 ft. and 150 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #1	
					8 Static water level: 95 ft. below land surface Date 6-24-75	
					10 Pumping level below land surfaces: 105 ft. after 1 hrs. pumping 10 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 10 g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
					12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 15 ft.	
					14 Nearest source of possible contamination: Feed ft. 300 Direction W Type Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Red Jacket</u> Model number <u>75N1</u> HP <u>3/4</u> Volts <u>230</u> Length of drop pipe <u>145</u> ft. capacity <u>10</u> g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					16 Remarks: elevation <p><u>3385 (TOPS)</u></p>	
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> 232 Business name <u>Scott City, KS 67871</u> License No. Address <u>Scott City, KS 67871</u> Signed <u>7-22-75</u> Authorized representative	
(use a second sheet if needed)						