


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>McPherson</u>	Township name <u>JACKSON</u>	Fraction <u>SE 1/4</u>	Section number <u>3</u>	Town number <u>19-5</u>	Range number <u>R-4-W</u>
Distance and direction from nearest town or city: <u>2 1/2 mi - 3 mi west</u> <u>2 McPherson</u>				3 Owner of well: <u>FRED HILL</u> Address: <u>McPherson, Kansas</u>		
Locate with "X" in section below: N  W S E 1 Mile				Sketch map: <u>WELL IN CENTER</u> <u>OF SE 1/4</u>		
2				4 Well depth: <u>195</u> ft. Date of completion <u>12-1-75</u> Well diameter <u>30</u> in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
From To				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
BLACK TOP SOIL 0 6				7 Casing: Material <u>TRANSITE</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>195</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No Weight <u>30</u> lbs./ft.		
CLAY - RED BUFF 6 63				8 Screen: Manufacturer <u>BUCKRA TILE CO.</u> Type <u>TRANSITE</u> Dia. <u>16" I.D.</u> Slot/gauze <u>1/8"</u> Length <u>52 ft.</u> Set between <u>143</u> ft. and <u>195</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/4"</u>		
GRAVEL-MEDIUM (DRY) 63 74				9 Static water level: <u>90</u> ft. below land surface Date <u>12-5-75</u>		
CLAY - WHITE 74 84				10 Pumping level below land surfaces: <u>120</u> ft. after <u>2</u> hrs. pumping <u>1200</u> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>1200</u> g.p.m.		
SANDS - MEDIUM 84 90				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
CLAY, DARK 90 98				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
SAND - Very fine 98 112				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> CLAY Depth: From <u>0</u> ft. to <u>15</u> ft.		
SANDS - MEDIUM (GOOD) 112 188				14 Nearest source of possible contamination: ft. <u>WELL</u> Direction <u>S.E.</u> Type <u>WELL</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
SHALE - BLUE 188 195				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>WESTERN LAND ROLLER</u> Model number <u>8th</u> HP <u>80</u> <u>6-1/2</u> HP Length of drop pipe <u>150</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
1495 188 1201				16 Remarks: elevation <u>1495 top</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
(use a second sheet if needed)				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>PETERSON BOERS INC 138</u> Business name License No. Address <u>Box 150 LINCOLN, KS</u> Signed <u>Wally Peterson</u> Date <u>12-25-75</u> Authorized representative		