

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County <u>MCPHERSON</u>	Fraction <u>SW 1/4 SW 1/4 NW 1/4</u>	Section number <u>9</u>	Township number T <u>19</u> S	Range number R <u>4</u> <u>W</u>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: <u>CHARLES FRANK</u> R.R. or street: <u>R.R. #3</u> City, state, zip code: <u>MCPHERSON, KS. 67460</u>		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>8"</u> in. Completion date <u>11-7-78</u> Well depth <u>105</u> ft.		
<p>DOMESTIC WELL</p>			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material <input type="checkbox"/> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>2</u> lbs./ft. Dia. <u>4</u> in. to <u>60</u> ft. depth Wall Thickness: inches or Dia. <u>4</u> in. to <u>60</u> ft. depth gage No. <u>225 in</u>		
			10. Screen: Manufacturer's name <u>AURORA TILE COMPANY</u> Type <u>PVC</u> Dia. <u>4 1/2"</u> Slot/gauze <u>1/16</u> Length <u>45 ft</u> Set between <u>60</u> ft. and <u>105</u> ft. <u>60</u> ft. and <u>105</u> ft. Gravel pack? <u>YES</u> Size range of material <u>1/4 in</u>		
			11. Static water level: <u>65</u> ft. below land surface Date <u>10-14, 78</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u>30</u> ft. after <u>2</u> hrs. pumping <u>12</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>15</u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <input checked="" type="checkbox"/> No <u> </u> Date <u> </u>		
			14. Well head completion: <u> </u> Pitless adapter <u>24</u> inches above grade		
			15. Well grouted? <u>YES</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>5</u> ft. to <u>15</u> ft.		
			16. Nearest source of possible contamination: ft. <u>150</u> Direction <u>NORTH</u> Type <u>SPEDIC TANK</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <u> </u> Not installed Manufacturer's name <u>MEYERS</u> Model number <u> </u> HP <u>1/2</u> Volts <u>230</u> Length of drop pipe <u>100</u> ft. capacity <u>10</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Remarks:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			(Use a second sheet if needed)		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief <u>PETERSON IRRIGATION</u> <u>138</u> Business name License No. Address <u>Box 150 LINDSBORG, KS</u> Signed <u>Mike Peterson</u> Date <u>11-3-78</u> Authorized representative		

19
4
9
SW SW NW
1/4 1/4 1/4