


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <u>McPherson</u> Fraction <u>NW 1/4 NW 1/4 SE 1/4</u> Section number <u>25</u> Township number <u>19</u> Range number <u>4</u> E W	
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>1/2 E 1/2 N 1 1/2 E 1/2 N. CONWAY</u>	
3. Owner of well: <u>N.G.L. Supply</u> R.R. or street: <u>1717 East Skelly Dr.</u> City, state, zip code: <u>Tulsa, Okla. 30</u>	
4. Locate with "X" in section below: Sketch map: 	
5. Type and color of material	
6. Bore hole dia. <u>10 3/8</u> in. Completion date <u>5/23/1975</u>	
7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <u>Transite</u> Height: Above or below	
Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>39</u> in.	
RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>30</u> lbs./ft.	
Dia. <u>16</u> in. to <u>78</u> ft. depth Wall thickness <u>3/4</u> inches or	
Dia. <u>16</u> in. to <u>78</u> ft. depth gage No. <u>34</u>	
10. Screen: Manufacturer's name <u>Johnson</u>	
Type <u>sawed</u> Dia. <u>16</u> in.	
Slot/gauze <u>3/16</u> Length <u>30</u> ft.	
Set between <u>78</u> ft. and <u>130</u> ft.	
Gravel pack? <u>yes</u> Size range of material <u>1/8 to 1/4</u>	
11. Static water level: <u>70</u> ft. below land surface Date <u>4/20/75</u>	
12. Pumping level below land surfaces: <u>85</u> ft. after <u>1</u> hrs. pumping <u>1150</u> g.p.m.	
<u>85</u> ft. after <u>1/2</u> hrs. pumping <u>1000</u> g.p.m.	
Estimated maximum yield <u>1150</u> g.p.m.	
13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>4/20/75</u>	
14. Well head completion: <u>39</u> inches above grade	
Pitless adapter <u>39</u> inches above grade	
15. Well grouted? <u>With: Neat cement</u> <u>Bentonite</u> <u>Concrete</u>	
Depth: From <u>0</u> ft. to <u>10</u> ft.	
16. Nearest source of possible contamination: <u>20</u> ft. Direction <u>NORTH</u> Type <u>drilling</u>	
Well disinfected upon completion? <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/>	
17. Pump: <u>Payne-Bowler</u> Not installed	
Manufacturer's name <u>Payne-Bowler</u>	
Model number <u>12-10RL</u> HP <u>7.5</u> Volts <u>500</u>	
Length of drop pipe <u>100</u> ft. capacity <u>500</u> g.p.m.	
Type: <u>Submersible</u> <u>Turbine</u> <u>Jet</u> <u>Reciprocating</u> <u>Centrifugal</u> <u>Other</u>	
18. Elevation: <u>1483</u> Topography: <u>Upland</u>	
19. Remarks: <u>19 - 40 22 NW 1/4 SE 1/4</u>	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Darling Drilling Co. 189</u> Business name License No. <u>121</u> Address <u>W. 4th Hutchinson, Kans.</u> Signed <u>Darling</u> Date <u>5-23-75</u> Authorized representative	