


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County McPherson	Fraction C 1/4 NE 1/4 NE 1/4	Section number 29	Township number T 19 S R 4 W	Range number
2. Distance and direction from nearest town or city: 8 E of Conway Street address of well location if in city:				3. Owner of well: N.C.R.A. R.R. or street: Box 908 City, state, zip code: Conway, KS McPherson, Ks.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 7/8 in. Completion date 12-18-76 Well depth 35 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other observation		
5. Type and color of material		From	To	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 160 lbs./ft. Dia. 4 1/2 in. to 35 ft. depth Wall thickness inches or Dia. in. to ft. depth gage No. 2 1/4		
Top Soil		0	3	10. Screen: Manufacturer's name R/B Type pvc Dia. 4 1/2 Slot/groove 1/16 Length 10 Set between 25 ft. and 35 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4		
Hard Brown Clay		3	8	11. Static water level: 24 ft. below land surface Date 12-18-76 mo./day/yr.		
Soft Brown Clay		8	22	12. Pumping level below land surfaces: 32 ft. after 1 hrs. pumping 3 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 3 g.p.m.		
Soft Sandy Clay		22	35	13. Water sample submitted: X Yes <input type="checkbox"/> No Date 12-18-76 mo./day/yr.		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 24 inches above grade		
Top Soil		0	3	15. Well grouted? <input type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Hard Brown Clay		3	9	16. Nearest source of possible contamination: ft. 40 Direction NE Type gas well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Soft Brown Clay		009	26	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Soft Sandy Clay		22	38	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. Signed Fredia Dorsa Date 1-13-77 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

220
sche 40
3/8
12
-40
22
CANE
1/4 1/4 1/4