


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County McPherson	Township name Jackson	Fraction S 1/2 of Sw 1/4	Section number 33	Town number 19 - S	Range number 4 - W		
Distance and direction from nearest town or city: 1/2 mi. E & 1 mi. S of Conway, Kan. Street address of well location if in city:			3 Owner of well: Loren Stubby Address: McPherson, Kansas					
Locate with "X" in section below: N  S 1 Mile			Sketch map:		4 Well depth: 65 ft. Date of completion 4-20-77 Well diameter 9 in.			
2 Type and color of material			From	To	5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			Loam		0	4	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			Clay		4	20	7 Casing: Material pvc Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 1/2 in. Diam. _____ Weight _____ lbs./ft. _____ 6 in. to 65 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No _____ in. to _____ ft. depth	
			Shale Red		20	65	8 Screen: Manufacturer _____ Type pvc Dia. 6 " Slot/gauze 1/8 Length 2 " Set between 37 ft. and 65 ft. perforation Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2	
			Water vein at		31		9 Static water level: 23 ft. below land surface Date 4-15-77	
			Water vein at		52		10 Pumping level below land surfaces: 1 1/8 ft. after 1 hrs. pumping 11 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 11 g.p.m.	
			Water vein at		58		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
							12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter 2 1/2 inches above grade	
							13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 4 ft. to 4 1/2 ft.	
							14 Nearest source of possible contamination: ft. 150 Direction NE Type Lateral Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(use a second sheet if needed)					15 Pump: yes <input type="checkbox"/> Not installed Manufacturer's name Flint & Walling Model number 5BA8 HP 1/2 Volts 230 Length of drop pipe 60 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Beattie Water Well Service Business name _____ License No. _____ Address Conway, Kansas Signed Fayne Beattie Date 5-7-77 Authorized representative					