

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY
PRINT CLEARLY

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: <i>McPherson</i>		Fraction <i>1/4 SW 1/4 SE 1/4</i>	Section number <i>34</i>	Township number <i>T 20 S</i>	Range number <i>R 1 W</i>
2. Distance and direction from nearest town or city: <i>7.50 East</i>		3. Owner of well: <i>Jimmy SCHRODER</i>			
Street address of well location if in city: <i>Canton KANSAS</i>		R.R. or street: <i>RR</i>			
		City, state, zip code: <i>CANTON KANSAS 67142</i>			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: <i>WELL # 1</i> <i>IRRIGATION WELL</i>		6. Bore hole dia. <i>18</i> in. Completion date <i>12-10-76</i> Well depth <i>40</i> ft.			
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
		9. Casing: Material <i>PVC</i> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <i>12</i> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <i>2.4</i> lbs./ft. Dia. <i>8</i> in. to <i>40</i> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <i>3/16"</i>			
5. Type and color of material		From	To	10. Screen: Manufacturer's name <i>CERTANTEED</i>	
<i>Top soil</i>		<i>0</i>	<i>3</i>	Type <i>P.V.C.</i> Dia. <i>8"</i>	
<i>SAND - FINE</i>		<i>3</i>	<i>10</i>	Slot/gauze <i>18</i> Length <i>20</i>	
<i>CLAY - BLUE</i>		<i>10</i>	<i>17</i>	Set between <i>20</i> ft. and <i>40</i> ft.	
<i>SAND - V. FINE</i>		<i>17</i>	<i>27</i>	Gravel pack? <i>NO</i> Size range of material <i>1/4"</i>	
<i>SAND - FINE TO MED.</i>		<i>27</i>	<i>37</i>	11. Static water level: <i>6</i> ft. below land surface Date <i>12-10-76</i>	
<i>SHALE BLUE</i>		<i>37</i>	<i>40</i>	12. Pumping level below land surfaces: <i>422</i> ft. after <i>1</i> hrs. pumping <i>120</i> g.p.m. ft. after <i>1</i> hrs. pumping <i>120</i> g.p.m. Estimated maximum yield <i>150</i> g.p.m.	
<i>Card 40 ft.</i>				13. Water sample submitted: <i>NO</i> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
				14. Well head completion: <i>NO</i> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
				15. Well grouted? <i>YES</i> <i>REDUCED CLAY</i> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <i>0</i> ft. to <i>10</i> ft.	
				16. Nearest source of possible contamination: ft. <i>2000</i> Direction <i>E</i> Type <i>WELL</i> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <i>136A</i> HP <i>1/2</i> Volts <i>115</i> Length of drop pipe <i>150</i> ft. capacity <i>150</i> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>PETERSON FAR INC</i> <i>136A</i> Business name License No. Address <i>Box 150 Winona, MN 55996</i> Signed <i>Walter Peterson</i> Date <i>1-12-77</i> Authorized representative	