


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Barton	Township name Pawnee Rock	Fraction SW$\frac{1}{4}$ of NW$\frac{1}{4}$	Section number 25	Town number T20S	Range number R15W
Distance and direction from nearest town or city: 4 mi. Northeast of Pawnee Rock, KS Street address of well location if in city:			3 Owner of well: Lee Turner (Dueser #1) Address: Great Bend, Kansas			
Locate with "X" in section below: N  W S 1 Mile			Sketch map:			4 Well depth: <u>36</u> ft. Date of completion <u>1-28-75</u> Well diameter <u>24</u> in.
2 Type and color of material			From	To	5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary	
Top soil			0	3	6 Use: ☐ Domestic ☐ Public supply ☐ Industry ☒ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐	
Brown clay & gray clay & gravel streaks			3	11	7 Casing: Material <u>Steel</u> Height: <u>above</u> below Threaded ☐ Welded ☒ Surface <u>12</u> in. Diam. <u>16</u> in. to <u>20</u> ft. depth Drive shoe? ☐ Yes ☒ No <u>16</u> in. to <u>36</u> ft. depth	
Sand & gravel			11	35	8 Screen: Manufacturer <u>Johnson Division</u> Type <u>125 Irrigator</u> <u>16"</u> <u>1/8</u> gauze <u>15'</u> Length <u>15'</u> Set between <u>20</u> ft. and <u>35</u> ft. <u>3/8-200</u> Fittings: Gravel pack ☒ Yes ☐ No Size range of material <u>3/8-200</u>	
Brown clay			35	36	9 Static water level: <u>13</u> ft. below land surface Date <u>1-28-75</u>	
					10 Pumping level below land surfaces: <u>N/C</u> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					11 Water sample submitted: ☐ Yes ☒ No Date ____	
					12 Well head completion: ☐ Pitless adapter <u>12</u> inches above grade	
					13 Well grouted? ☒ Yes ☐ No ☒ Neat cement ☐ Bentonite ☐ Depth: From <u>0</u> ft. to <u>10</u> ft.	
					14 Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? ☐ Yes ☒ No	
					15 Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other	
(use a second sheet if needed)						
16 Remarks: elevation Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Clarke Well & Eq., Inc.</u> <u>185</u> Business name License No. Address <u>Great Bend, KS</u> Signed <u>D.W. Clarke</u> Date <u>1-28-75</u> Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5